

Water Quality Inspection Report_ April 2024 to March 2025

Sampling location: **Miho Fureai Park**

Supply route: Yatsu Filtration Plant→ Ohirayama Reservoir

Items for Inspection	Units	Criterion Value	Sampling Date													Maximum	Minimum	Average
			8-Apr-2024	13-May-2024	3-Jun-2024	1-Jul-2024	14-Aug-2024	2-Sep-2024	2-Oct-2024	6-Nov-2024	2-Dec-2024	15-Jan-2025	3-Feb-2025	3-Mar-2025				
Air temperature	°C	—	19.7	20.3	22.6	25.1	29.5	29.6	28.8	18.6	15.3	11.8	11.3	10.4	29.6	10.4	20.3	
Water temperature	°C	—	15.8	19.2	20.3	21.7	26.4	24.5	25.5	20.3	15.6	7.7	11.2	12.1	26.4	7.7	18.4	
1 Standard plate count bacteria	per ml	100 or less	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
2 Bacillus Coli	—	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Detected 0 : Not Detected 12			
3 Cadmium or its chemical compounds	mg/L	0.003 or less	<0.0001	—	—	<0.0001	—	—	<0.0001	—	—	<0.0001	—	—	<0.0001	<0.0001	<0.0001	
4 Mercury or its chemical compounds	mg/L	0.0005 or less	<0.00005	—	—	<0.00005	—	—	<0.00005	—	—	<0.00005	—	—	<0.00005	<0.00005	<0.00005	
5 Selenium or its chemical compounds	mg/L	0.01 or less	<0.0005	—	—	<0.0005	—	—	<0.0005	—	—	<0.0005	—	—	<0.0005	<0.0005	<0.0005	
6 Lead or its chemical compounds	mg/L	0.01 or less	<0.0005	—	—	<0.0005	—	—	<0.0005	—	—	<0.0005	—	—	<0.0005	<0.0005	<0.0005	
7 Arsenic or its chemical compounds	mg/L	0.01 or less	0.0003	—	—	<0.0003	—	—	0.0005	—	—	<0.0003	—	—	0.0005	<0.0003	<0.0003	
8 Hexavalent chromium or its chemical compounds	mg/L	0.02 or less	<0.0005	—	—	<0.0005	—	—	<0.0005	—	—	<0.0005	—	—	<0.0005	<0.0005	<0.0005	
9 Nitrate nitrogen	mg/L	0.04 or less	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	
10 Cyanide ion/ Zion chloride	mg/L	0.01 or less	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	<0.001	<0.001	
11 Nitrate nitrogen/ Nitrite nitrogen	mg/L	10 or less	0.6	0.4	0.5	0.5	0.6	0.7	0.4	0.6	0.6	0.5	0.5	0.5	0.7	0.4	0.5	
12 Flourine or its chemical compounds	mg/L	0.8 or less	0.06	0.06	0.06	<0.05	0.05	<0.05	0.06	<0.05	0.05	0.06	0.06	0.06	0.06	<0.05	<0.05	
13 Boron or its chemical compounds	mg/L	1.0 or less	0.025	—	—	0.018	—	—	0.034	—	—	0.032	—	—	0.034	0.018	0.027	
14 Carbon tetrachloride	mg/L	0.002 or less	<0.0002	—	—	<0.0002	—	—	<0.0002	—	—	<0.0002	—	—	<0.0002	<0.0002	<0.0002	
15 Dioxane-1.4	mg/L	0.05 or less	<0.005	—	—	<0.005	—	—	<0.005	—	—	<0.005	—	—	<0.005	<0.005	<0.005	
16 Cis-1.2 dichloroethylene and Trans-1.2 dichloroethylene	mg/L	0.04 or less	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	<0.001	<0.001	
17 Dichloromethane	mg/L	0.02 or less	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	<0.001	<0.001	
18 Tetrachloroethylene	mg/L	0.01 or less	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	<0.001	<0.001	
19 Trichloroethylene	mg/L	0.01 or less	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	<0.001	<0.001	
20 Benzene	mg/L	0.01 or less	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	<0.001	<0.001	
21 Chloric acid	mg/L	0.6 or less	<0.06	<0.06	<0.06	<0.06	<0.06	<0.06	<0.06	<0.06	<0.06	<0.06	<0.06	<0.06	<0.06	<0.06	<0.06	
22 Chloroacetic acid	mg/L	0.02 or less	<0.002	—	—	<0.002	—	—	<0.002	—	—	<0.002	—	—	<0.002	<0.002	<0.002	
23 Chloroform	mg/L	0.06 or less	0.005	—	—	0.005	—	—	0.008	—	—	0.002	—	—	0.008	0.002	0.005	
24 Dichloroacetate	mg/L	0.03 or less	<0.002	—	—	<0.002	—	—	0.002	—	—	<0.002	—	—	0.002	<0.002	<0.002	
25 Dibromochloromethane	mg/L	0.1 or less	<0.001	—	—	<0.001	—	—	0.002	—	—	0.001	—	—	0.002	<0.001	<0.001	
26 Bromic acid	mg/L	0.01 or less	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	<0.001	<0.001	
27 Total trihalomethane	mg/L	0.1 or less	0.007	—	—	0.007	—	—	0.014	—	—	0.005	—	—	0.014	0.005	0.008	
28 Trichloroacetic acid	mg/L	0.03 or less	<0.002	—	—	0.002	—	—	0.003	—	—	<0.002	—	—	0.003	<0.002	<0.002	
29 Bromodichloromethane	mg/L	0.03 or less	0.002	—	—	0.002	—	—	0.004	—	—	0.002	—	—	0.004	0.002	0.003	
30 Bromoform	mg/L	0.09 or less	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	—	—	<0.001	<0.001	<0.001	
31 Formaldehyde	mg/L	0.08 or less	<0.004	—	—	<0.004	—	—	<0.004	—	—	<0.004	—	—	<0.004	<0.004	<0.004	
32 Zinc or its chemical compounds	mg/L	1.0 or less	<0.005	—	—	<0.005	—	—	<0.005	—	—	<0.005	—	—	<0.005	<0.005	<0.005	
33 Alminum or its chemical compounds	mg/L	0.2 or less	0.050	—	—	0.044	—	—	0.072	—	—	0.046	—	—	0.072	0.044	0.053	
34 Iron or its chemical compounds	mg/L	0.3 or less	<0.005	—	—	<0.005	—	—	<0.005	—	—	<0.005	—	—	<0.005	<0.005	<0.005	
35 Copper or its chemical compounds	mg/L	1.0 or less	<0.005	—	—	<0.005	—	—	<0.005	—	—	<0.005	—	—	<0.005	<0.005	<0.005	
36 Sodium or its chemical compounds	mg/L	200 or less	6	—	—	6	—	—	7	—	—	7	—	—	7	6	7	
37 Manganese or its chemical compounds	mg/L	0.05 or less	<0.0003	—	—	<0.0003	—	—	<0.0003	—	—	<0.0003	—	—	<0.0003	<0.0003	<0.0003	
38 Chloride ion level	mg/L	200 or less	4	4	4	4	4	4	4	4	4	6	7	7	7	4	5	
39 Calcium/magnesium etc. (hardness)	mg/L	300 or less	52	—	—	44	—	—	59	—	—	59	—	—	59	44	54	
40 Evaporation residue	mg/L	500 or less	91	—	—	75	—	—	108	—	—	91	—	—	108	75	91	
41 Anionic detergents	mg/L	0.2 or less	<0.02	—	—	<0.02	—	—	<0.02	—	—	<0.02	—	—	<0.02	<0.02	<0.02	
42 Geosmin *1	mg/L	0.00001 or less	<0.000001	—	—	<0.000001	—	—	<0.000001	—	—	<0.000001	—	—	<0.000001	<0.000001	<0.000001	
43 2-methylisoborneol *2	mg/L	0.00001 or less	<0.000001	—	—	<0.000001	—	—	<0.000001	—	—	<0.000001	—	—	<0.000001	<0.000001	<0.000001	
44 Nonionic surfactants	mg/L	0.02 or less	<0.005	—	—	<0.005	—	—	<0.005	—	—	<0.005	—	—	<0.005	<0.005	<0.005	
45 Phenols	mg/L	0.005 or less	<0.0005	—	—	<0.0005	—	—	<0.0005	—	—	<0.0005	—	—	<0.0005	<0.0005	<0.0005	
46 TOC(Organic material)	mg/L	3 or less	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.3	0.3	0.2	0.3	0.2	0.3	
47 pH Count	—	From 5.8 to 8.6	7.7	7.7	7.6	7.6	7.9	7.4	7.9	7.5	7.9	7.8	7.6	7.6	7.9	7.4	7.7	
48 Flavor	—	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	Abnormal 0 : No Abnormalities 12			
49 Odour	—	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	No abnormalities	Abnormal 0 : No Abnormalities 12			
50 Chromaticity	°C	5 or less	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	
51 Turbidity	°C	2 or less	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	
Chlorine residue	mg/L	0.1 or more ※3	0.44	0.44	0.34	0.38	0.4	0.58	0.34	0.38	0.50	0.34	0.32	0.38	0.58	0.32	0.40	
Findings			Meets water quality standards	Above items meet necessary water quality standards.	Above items meet necessary water quality standards.	Meets water quality standards	Above items meet necessary water quality standards.	Above items meet necessary water quality standards.	Meets water quality standards	Above items meet necessary water quality standards.	Above items meet necessary water quality standards.	Meets water quality standards	Above items meet necessary water quality standards.	Above items meet necessary water quality standards.				
Duration of Inspection			from 8-Apr	13-May	3-Jun	1-Jul	14-Aug	2-Sep	2-Oct	6-Nov	2-Dec	15-Jan	3-Feb	3-Mar				
Inspection Agency			to 19-Apr	14-May	4-Jun	12-Jul	15-Aug	3-Sep	15-Oct	7-Nov	3-Dec	24-Jan	4-Feb	5-Mar				
			Water Quality Management Division, Waterworks Department, Waterworks Bureau, City of Shizuoka (152-9 Ihara-cho, Shimizu-ku, Shizuoka City, Japan)															

- Notes:
- Water quality inspections are carried out by methods set by the Minister of Health, Labour and Welfare (MHLW Notice 261, July 22, 2003)
 - The symbol "<" to the left of values indicates a number less than said value
 - *1 Proper name: (4S, 4aS, 8aR) -Octahydro-4,8a-Dimethylnaphthalene-4a(2H)-All
 - *2 Proper name: 1,2,7,7-Tetramethylbicyclo[2,2,1]Heptane-2-All
 - *3 Isolated residual chlorine as it falls under Article 1, Part 3 of Enforcement Regulation 17 in the Waterworks Law

This is to certify that the above record is a translation of the original Water Quality Inspection Results.
Shimizu Port Authority